ASSURED BIO LABS, LLC

ENVIRONMENTAL MICROBIOLOGY & WATER

Tennessee Division of Water Resources Lab ID: 03147

228 Midway Ln, Ste B, Oak Ridge, TN 37830

REVIEWED

By Mikayla Mangrum, PhD at 9:43 am, Oct 21, 2026

CERTIFICATE OF WATER ANALYSIS

Basic Water Panel

PREPARED FOR

Inspector:	customer name
Company:	company
Project Name:	
Project Number:	
Number of Samples:	1

SUMMARY

Assured Bio ID:	unique identifier
Date Collected:	10/15/2026
Date Received:	10/16/2026
Date Reported:	10/21/2026
Analyst(s):	Dr. E. Sobek, D. Sobek, Z. Whitley

TN Department of Environment & Conservation

SAMPLE RESULTS

AB Identifier	Sample ID	Description
unique identifier 1	W	Basic Home Panel

	Result	Reporting Limit	Unit
Microbiology			
Coliform	Present	1 organism/100 ml	P/A
E. coli	BDL	1 organism/100 ml	P/A
Chemistry			
Lead	BDL	0.005	ppm
Nitrate (NO_3^--N)	BDL	0.23	ppm
Nitrite (NO_2-N)	BDL	0.015	ppm
pH	7.00	1.0	

Reporting Limit (RL): The lowest concentration of an analyte that can be reported with a defined and reproducible level of certainty. Results reported as "<" indicate that the analyte was not detected at or above the stated Reporting Limit. BDL = less than reporting limit. For Colisure Presence/Absence testing, the stated reporting limit represents the method's detection capability. The test detects total coliforms and *E. coli* at 1 organism per 100 mL sample.

For EPA standards, reference levels, abbreviations, and result interpretation, see the Water Analysis Reference Guide included with this report.

WATER ANALYSIS REFERENCE GUIDE

EPA Standard / Reference Level: Values may include EPA Maximum Contaminant Levels (MCLs), Action Levels (ALs), Secondary Maximum Contaminant Levels (SMCLs), Maximum Contaminant Level Goals (MCLGs), or other interpretive reference values. EPA drinking-water regulations apply to public water systems and generally do not regulate private wells or untreated source waters such as springs, ponds, and rivers. Values are provided for comparison and interpretation only and do not, by themselves, establish potability.

Coliform / E. coli: No detection is recommended for drinking water from private wells and other untreated sources. For public water systems, EPA regulates total coliform through treatment-technique and assessment requirements rather than a simple numerical MCL. The E. coli MCLG is zero. Positive results indicate a potential pathway for microbial contamination and warrant investigation and appropriate corrective action. For positive private-well results, refer to the Tennessee Healthy Well Manual for well-disinfection guidance.

Key abbreviations: MCL = Maximum Contaminant Level | AL = Action Level | SMCL = Secondary Maximum Contaminant Level | MCLG = Maximum Contaminant Level Goal | ND = Not Detected | nps = no published standard | P/A = Presence / Absence | MPN = Most Probable Number | NTU = Nephelometric Turbidity Units | ppm = mg/L | µS/cm = microsiemens per centimeter | PtCo = platinum-cobalt color units

Analyte	EPA Standard / Reference Level	Interpretation / significance
Coliform / *E. coli*	ND recommended*	Coliform indicates possible contamination pathways; *E. coli* is a stronger indicator of fecal contamination.
Lead	0.015 ppm AL	Usually associated with plumbing or service-line corrosion; toxic, especially to children and developing fetuses.
Nitrate (as N)	10 ppm MCL	Often linked to fertilizers, septic systems, sewage, or animal waste; elevated levels are hazardous to infants.
Nitrite (as N)	1 ppm MCL	Similar sources to nitrate; elevated levels can cause methemoglobinemia in infants.
pH	6.5-8.5 SMCL	Influences corrosion, metal solubility, treatment effectiveness, and taste.

**ND = Not Detected. EPA public-water compliance requirements vary by analyte and system; values above are provided as report interpretation references.*

Selected References

- EPA Manual of the Certification of Laboratories Analyzing Drinking Water, 5th Edition. EPA 815-R-05-004, January 2005.
- IDEXX SimPlate® for HPC Unit Dose Instructions. 06-03208-10, 2016..
- Environmental Protection Agency. 2005. EPA Manual for the Certification of Laboratories Analyzing Drinking Water. Criteria and Procedures Quality Assurance. Fifth Edition. Cincinnati, Ohio

Methods of Analysis

Assured Bio Labs, LLC uses the following Standard Operating Procedures for the analysis of samples:

CD 205: Coliform Presence Absence Test According to the EPA Manual for the Certification of Laboratories Analyzing Drinking Water, CD 219: Hach Water Testing (DR 3900) Using TNT, Powder Pillow, or Other Photospectroscopic Methods.

Assured Bio Labs, LLC uses the following Standard Operating Procedures for the analysis of samples:

CD 224 Heterotrophic Plate Count Using the SimPlate® Method

Reporting Limits

Method Detection Limit: The American Industrial Hygiene Association defines this term in AIHA LAP, LLC Policy Document – Module 9 as "The minimum concentration of an analyte that, in a given matrix and with a specific method, has a 99 percent probability of being identified, qualitatively or quantitatively measured, and reported to be greater than zero."

Reporting Limit: The American Industrial Hygiene Association defines this term in AIHA LAP, LLC

Policy Document – Module 9 as "The lowest concentration of analyte in a sample that can be reported with a defined, reproducible level of certainty."

Range of Detection: The reporting limit to the maximum reporting limit giving the currently used testing methodology at Assured Bio labs LLC. Any amount reported outside of this range should be considered an estimate. Values outside of this range may be reported as greater than (">") or less than ("<").

Additional Comments

The analytical data included in this report reflect only the conditions of the material sampled and submitted to the laboratory for analysis at the time of collection. We can make no claims to the safety or potability of water. The results included in this report may not be used for past or future environmental conditions. The results apply to the sample(s) as received. Potential interferences may exist for certain tests. When such interferences are detected, they will be report when potentially affecting the result and the Maximum Contaminant Level. A list of methods used can be provided upon request. If you require a certain method please contact us for further guidance.

The results are reported as the Most Probable Number per milliliter (MPN/ml) with the upper and lower 95% confidence limits provided per sample. These values are derived from the IDEXX SimPlate® Most Probable Number Table. Samples with less than one positive well are reported as below detectable limits with a 95% confidence interval of <0.03-<1.4 MPN/ml.

Limitations

ASSURED BIO LABS, LLC MAKES NO WARRANTIES AND EXPRESSLY DISCLAIMS THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR PURPOSE. INSPECTOR ACKNOWLEDGES THAT ASSURED BIO LABS, LLC HAS NOT INSPECTED THE SUBJECT PROPERTY AND THAT THE INSPECTOR IS SOLELY RESPONSIBLE FOR CHOOSING THE LOCATION OF SAMPLE COLLECTION. ASSURED BIO LABS, LLC SHALL NOT BE LIABLE TO INSPECTOR FOR ANY INCIDENTAL, CONSEQUENTIAL, SPECIAL OR PUNITIVE DAMAGES OF ANY KIND OR NATURE, INCLUDING, WITHOUT LIMITATION, ANY DAMAGES TO PROPERTY OR PERSONAL INJURY WHETHER SUCH LIABILITY IS ASSERTED ON THE BASIS OF CONTRACT, TORT, OR OTHERWISE, EVEN IF ASSURED BIO LABS, LLC HAS BEEN WARNED OF THE POSSIBILITY OF SUCH LOSS OR DAMAGE. UNDER NO CIRCUMSTANCES SHALL ASSURED BIO LABS, LLC BE LIABLE FOR DAMAGES UNDER OR ARISING OUT OF THIS REPORT IN AN AMOUNT EXCEEDING THE AMOUNT PAID BY THE INSPECTOR TO ASSURED BIO LABS, LLC FOR THIS ANALYSIS AND REPORT. THIS REPORT IS FOR THE SOLE USE OF THE INSPECTOR AND CREATES NO THIRD-PARTY BENEFICIARIES OR RIGHTS HEREUNDER. THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL WITHOUT PRIOR APPROVAL FROM ASSURED BIO LABS, LLC.